#### CALIFORNIA ENERGY COMMISSION

1516 NINTH STREET SACRAMENTO, CA 95814-5512



# STATE OF CALIFORNIA ENERGY RESOURCES CONSERVATION AND DEVELOPMENT COMMISSION

In the Matter of:	)	Docket No. 97-AFC-2C
CALPINE CONSTRUCTION	)	Order No. 03-0611-01(k)
FINANCE COMPANY, L.P.'S	)	Order Approving Amendment To
SUTTER POWER PROJECT	)	Change Startup Emission Limits and
	)	Other Air Quality Conditions

Calpine Construction Finance Company, L.P. (Calpine) filed a petition to amend several Air Quality Conditions of Certification in the Commission Decision for the Sutter Power Project, subsequently renamed the Sutter Energy Center, Docket No. 97-AFC-2C. The request is to modify air quality emission and performance limits for startup and shutdown of the project's gas combustion turbines and make other technical changes

The Commission approves Calpine's' proposed changes in accordance with Title 20, Section 1769 (a) (3) of the California Code of Regulations.

### **COMMISSION FINDINGS**

Based on staff's analysis, and adoption of the proposed modifications to the conditions of certification, the Commission concludes that the proposed changes will not result in any significant impacts to public health and safety or the environment. The Commission finds that:

- 1. There will be no new or additional unmitigated significant environmental impacts associated with the proposed changes.
- 2. The facility will remain in compliance with all applicable laws, ordinances, regulations, and standards, subject to the provisions of Public Resources code section 25525.
- The changes will be beneficial to the public, applicant, or interveners. In this
  case, the amendment will benefit the applicant by modifying shutdown and
  startup requirements and simplifying operational emission limits to allow more
  efficient project operation without increasing any daily, quarterly, or annual
  emission limits.
- 4. There have been substantial changes in circumstances resulting in information that was not available to the parties prior to the Commission certification. These changes include new information regarding startup and shutdown performance of the project's combustion turbines.

#### **ORDER**

The Commission hereby adopts the following changes to the Sutter Power Project Decision:

Modified Air Quality Conditions (new language underlined, deletions struck out).

AQ-7 The facility shall not discharge emit into the atmosphere from any source whatsoever such quantities of air contaminants or other materials which that cause injury, detriment, a public nuisance, or annoyance to any considerable number of persons or the public, or which endanger the comfort, repose, health or safety of any such persons or the public, or which cause, or have a natural tendency to cause, injury or damage to business or property. (District General ATC Permit Condition a).

<u>Verification:</u> As part of the <u>semiannual quarterly</u> Air Quality Reports (as required by AQ-430), the project owner shall include the date and time when any accidental release of air contaminants or other materials occur. The Air Quality Report shall also include the reason for the accidental release and measures taken to correct it.

AQ-8 The facility shall not emit <u>into the atmosphere</u> particulate emissions from any single source which exceed an opacity equal to or greater than twenty percent (20%) for a period aggregating more than three (3) minutes in any one (1) hour, excluding uncombined water vapor. (District General ATC Permit Condition b).

<u>Verification:</u> As part of the <u>semiannual quarterly</u> Air Quality Reports (as required by AQ-430), the project owner shall include an explanation and the date, time, and duration of any violation of this Condition.

**AQ-9** The facility shall not discharge emit into the atmosphere into the atmosphere from any source particulate matter in excess of 0.3 grains per cubic foot of gas at standard conditions. When the source involves a combustion process, the concentration must be calculated to 12 per cent carbon dioxide (CO 2). (District General ATC Permit Condition c).

<u>Verification:</u> As part of the annual Air Quality Reports, the project owner shall submit to the District and CPM the annual source test and specify the level of particulate matter in grains per cubic foot of gas at standard conditions.

AQ-10The facility shall not discharge emit into the atmosphere in any one hour from any source whatsoever fumes in total quantities in excess of the amounts as prescribed for and shown in District's Rule 3.3 Table of Allowable Rate of Emission Based on Process Weight Rate. (District General ATC Permit Condition d).

<u>Verification:</u> As part of the <u>semiannual quarterly</u> Air Quality Reports (as required by AQ-430), the project owner shall indicate the date, time, and duration of any violation of this Condition.

**AQ-11** The facility shall not discharge into the atmosphere, from any single source of emission whatsoever, any sulfur oxides in excess of 0.2 percent by volume (2,000 ppm) collectively calculated as sulfur dioxide (SO2). (District General ATC Permit Condition e).

**Verification:** As part of the annual Air Quality Reports, the project owner shall submit to the District and CPM the annual source test and specify the level of sulfur oxides in percent by volume of gas at standard conditions.

AQ-12 Project owner shall not build, erect, install, or use any article, machine, equipment or other contrivance to conceal an emission which would otherwise constitute a violation of the Health and Safety Code of the State of California or of these Rules and Regulations.

<u>Verification:</u> Refer to AQ-33 through AQ-36. The project owner shall obtain approval from the District and the CPM prior to installing any new equipment that results in releasing air contaminants.

AQ-13 Project owner shall take every reasonable precaution not to cause or allow the emissions of fugitive dust from being airborne beyond the property line from which the emission originates, from any construction, handling or storage activity, or any wrecking, excavation, grading, clearing of land or solid waste disposal operation. Reasonable precautions shall include, but are not limited to: use, where possible, of water or chemicals for control of dust in the demolition of existing buildings or structures, construction operations, construction of roadways, or the clearing of land; application of asphalt, oil, water, or suitable chemical on dirt roads, material stockpiles, and other surfaces which can give rise to airborne dusts; other means approved by the Air Pollution Control Officer. (FRAQMD General ATC Permit Condition g).

**<u>Verification:</u>** Refer to conditions AQ-1 through AQ-6.

- **AQ-14** In the case of shut-down or re-start<u>up</u> of air pollution <u>control</u> equipment for necessary scheduled maintenance, the intent to shut down such equipment shall be reported to the Air Pollution Control Officer at least twenty-four (24) hours prior to the planned shutdown. Such prior notice may include, but is not limited to, the following:
  - a. Identification of the specific equipment to be taken out of service as well as its location and permit number;

- b. The expected length of time that the air pollution control equipment will be out of service;
- c. The nature and quantity of emissions of air contaminants likely to occur during the shut-down period;
- d. Measures such as the use of off-shift labor and equipment that will be taken to minimize the length of the shutdown period.
- e. The reasons that it would be impossible or impractical to shut down the source operation during the maintenance period.

(FRAQMD General ATC Permit Condition h).

<u>Verification:</u> As part of the <u>semiannualquarterly</u> Air Quality Report (as required by AQ-430), the project owner shall include the dates of the equipment maintenance schedule including when each piece of equipment will be shutdown and when it will start-up.

AQ-15 In the event that any emission source, air pollution control equipment, or related facility breaks down in such a manner which may cause the emission of air contaminants in violation of any permit condition or applicable rules or regulations, other than as exempted herein, the licensee shall immediately notify the Air Pollution Control Officer of such failure or breakdown and subsequently provide a written statement giving all pertinent facts, including the estimated duration of the breakdown. The Air Pollution Control Officer shall be notified when the condition causing the failure or breakdown has been corrected and the equipment is again in operation. (FRAQMD General ATC Permit Condition i).

<u>Verification:</u> As part of the <u>semiannual quarterly</u> Air Quality Report (as required by AQ-430), the project owner shall include the date and duration of all equipment breakdowns, the cause of the breakdown, how it was corrected, and the measures that will be used to prevent the problem from occurring again.

AQ-16 Project owner shall submit an application for a Federal Operating Permit Title- V within 12 months after operational startup. (FRAQMD General ATC Permit Condition j).

<u>Verification:</u> The project owner shall submit to the CPM a copy of the report at the time of filing with the District.

**AQ-17** Project owner shall prepare and submit to the District a Toxic Hot Spots emission inventory by the first month of August following the first full calendar year of facility operational history. (FRAQMD General ATC Permit Condition k).

<u>Verification:</u> As part of the semiannual Air Quality Report (as required by AQ-43), tThe project owner shall submit to the District and the CPM an inventory of all Toxic Hot Spots emissions.

**AQ-18** A PSD permit must be obtained from the USEPA before commencement of facility operations. (FRAQMD General ATC Permit Condition I).

<u>Verification:</u> At least 90 days prior to commencement of facility operations, the project owner shall submit to the CPM a copy of the PSD permit from the US EPA.

AQ-19 The equipment is subject to the federal NSPS codified at 40 CFR Part 60, Subparts A (General Provisions), Db (Standards of Performance for Industrial-Commercial-Institutional Steam Generating Systems), and GG (Standards of Performance for Stationary Gas Turbines), Compliance with all applicable provisions of these regulations is required. (FRAQMD General ATC Permit Condition m).

<u>Verification:</u> As part of the first <u>semi-annualguarterly</u> Air Quality Report <u>(as required by AQ-40)</u>, the project owner shall submit to the District and CPM a copy of a statement of compliance with the above federal applicable provisions and regulations.

AQ-20 Project owner shall meet the provisions of the Federal Acid Rain Program Title-IV by filing an Acid Rain permit 24 months before operational startup and by certifying CEMS for NOx and O2 within 90 days after operational startup.

(FRAQMD General ATC Permit Condition n).

<u>Verification:</u> The project owner shall provide the District and the CPM with a copy of the Acid Rain permit within 90 days after the permit is approved. Refer to AQ-33 for verification.

**AQ-21** Project owner shall file an RMP with the Sutter County office in charge of the prevention of accidental releases prior to operational startup. (FRAQMD General ATC Permit Condition o).

**<u>Verification:</u>** Refer to Hazardous Materials condition and verification HazMat-2.

AQ-22 The Authority To Construct (ATC) is not transferable from one location to another, or from one person to another without the written approval of the APCO. (FRAQMD General ATC Permit Condition p).

<u>Verification:</u> At least sixty days in advance, the project owner shall notify, in writing, the District and the CPM of any intended transfer of ownership or location and obtain written approval prior to any transfer.

**AQ-23** District personnel shall be allowed access to the plant site and pertinent records at all reasonable times for the purposes of inspections, surveys, collecting samples, obtaining data, reviewing and copying air contaminant emission records

and otherwise conducting all necessary functions related to this permit. (FRAQMD General ATC Permit Condition q).

<u>Verification:</u> During site inspection, the project owner/operator shall make the plant logs available to the District, California Air Resources Board (CARB), and Commission staff.

**AQ-24** Project owner shall maintain a copy of all District permits at the facility. (FRAQMD General ATC Permit Condition r).

<u>Verification:</u> During site inspection, the project owner/operator shall make all plant permits available to the District, California Air Resources Board (CARB), and Commission staff.

AQ-25 Combustion turbine exhaust stacks shall exhaust at a height of 145 feet and the maximum diameter shall not exceed 18 feet. (FRAQMD General ATC Permit Condition s).

<u>Verification:</u> The project owner/operator shall make the site available for inspection to the District, California Air Resources Board (CARB), and Commission staff.

AQ-26 Project owner shall submit to the District and the Energy Commission ERC option contracts or final signed contracts for the project's ERC liability, except for PM10, as listed in condition AQ-421 prior to the Energy Commission's Final Decision on the project. (FRAQMD General ATC Permit Condition t).

<u>Verification:</u> At least 10 days prior to the Commission adoption of the final decision on the project, the Project owner shall have provided copies of all option contracts or signed contracts required by this Condition.

AQ-27 Calpine has produced evidence indicating that it has an enforceable right to ERCs located in another District. These ERCs cannot be used until the District Board adopts an approving resolution and enters into an MOU with the other District. The District intends to act on the resolution and MOU as soon as practicable after CEC completes an environmental analysis document and the criteria in Section 15253, Subdivision (b) of the CEQA Guidelines are met. (FRAQMD General ATC Permit Condition v.)

<u>Verification:</u> At least 30 days prior to the start of construction, Project owner shall provide a copy of the signed MOU to the CPM.

AQ-28 Project owner may substitute interpollutant offsets of VOCs (ROCs) for NOx at a 2.0 to 1.0 interpollutant offset ratio pursuant to Rule 10.1, Section E.2, d. (FRAQMD General ATC Permit Condition w).

<u>Verification:</u> The project owner shall submit to the District and the CPM a copy of the offsets calculations that satisfy AQ-421 if it chooses to use the interpollutant substitution offset ratio specified in this Condition.

AQ-29 The facility shall exclusively use California PUC pipeline quality natural gas as fuel. The fuel gas total sulfur and heat content will be determined and reported to the District by collecting and analyzing a sample on a monthly basis or by providing monthly certification of the natural gas total sulfur and/or heat content issued by the natural gas distributor. (FRAQMD General ATC Permit Condition x).

<u>Verification:</u> As part of the <u>semi-annualquarterly</u> Air Quality Report (as required by AQ-430), the project owner shall submit to the District and CPM a copy of the natural gas analysis or certification issued by the natural gas distributor to satisfy this Condition.

**AQ-30** All basic and control equipment is to be operated and maintained in accordance with vendors' recommended practices and procedures. (FRAQMD General ATC Permit Condition y).

**Verification:** Refer to AQ-14 verification.

AQ-31 The maximum heat input allowed to each permitted internal and external combustion emissions unit gas turbine and duct burner, expressed in MMBtu units on a High Heating Value basis (HHV), shall not exceed the limits indicated in the table below: (FRAQMD specific ATC Permit Condition a).

<b>Emission Unit</b>	MMBtu/hour	MMBtu/day (1)	MMBtu/year (2)		
CTG-1	1,900	45,600	16,644,000		
CTG-2	1,900	45,600	16,644,000		
Duct Burner-1	170	4,080	928,200		
Duct Burner-2	170	4,080	928,200		
(1) Based on 24 hour-day					
(2) Based on 365 days/year					

<u>Verification:</u> As part of the <u>semi-annualguarterly</u> Air Quality Reports (as required by AQ-430), the project owner shall document the date and time when the hourly fuel consumption exceeds the hourly limits included in this Condition. The reports shall include a summary of hourly and daily fuel consumption in MMBtu [high heating value (HHV)] for all the cases indicated in the table above. The January Air Quality Report shall also include information on the amount of fuel consumed, in MMBtu (HHV), in the prior calendar year.

**AQ-32** The following definitions and limitations shall apply: (FRAQMD specific ATC Permit Condition b).

- (1) CTG startups are defined as the time period commencing with the introduction of fuel flow to the gas turbine and ending at the start of the first hour period when the NOx concentrations do not exceed 2.5 ppmvd at 15% O<sub>2</sub> averaged over 1-hour and the CO concentrations do not exceed 4.0 ppm at 15% O<sub>2</sub> averaged over 1 hour.
- (2) For each CTG, a startup shall not exceed 480360 consecutive minutes.
- (3) Shutdowns are defined as the time period commencing with a 15 minute period during which the 15 minute average NOx concentrations exceed 2.5 ppmvd at 15% O2 or the 15 minute average CO concentration exceeds 4.0 ppm at 15% O2 and ending when the fuel flow to the gas turbine is discontinued.
- (4) For each CTG, a shutdown shall not exceed 60 consecutive minutes.
- (5) The maximum duration of startups per CTG shall be 400 hours per year and 102 hours per calendar quarter.
- (6) The maximum duration of shutdowns per CTG shall be 300 hours per year, and 76 hours per calendar quarter.
- (7) Compliance with the above yearly limits shall be calculated based on a rolling 12-month average.
- (8) All emissions during startups and shutdowns shall be included in all calculations of daily, <u>quarterly</u> and annual mass emissions required by this permit.
- (9) For each CTG the maximum number of Duct Burner the total hours of combusting fuel hours of operation shall not exceed 5,460 per calendar year.
- (10) For each CTG the maximum number total hours of Power Augmentation Steam Injection hours shall not exceed 2,000 hours per calendar year.
- (11) For each CTG tThe maximum hourly emissions from each gas turbine/duct burner rates (lbs/hr) are given in the table below and shall be averaged over any rolling three hour period, except for the NOx emissions, and all hourly startup emission rates, which willshall be averaged over a one hour period. The emission limits in the Total Startup column are shown as pounds per startup: Additionally excepting the total emissions per startup and total emissions per shutdown which are not averaged over any time frame.

Pollut ant	CTG	CTG+ Duct Burner	CTG+ Duct Burner + Steam Injection	CTG+ Steam Injection	Startup	Total Startup Ibs/event	Shutdown
<del>NOx</del>	<del>16.8</del>	<del>18.2</del>	<del>19.1</del>	<del>17.7</del>	<del>175</del>	<del>510</del>	<del>12.1</del>
CO	<del>16.7</del>	<del>20.1</del>	<del>34.3</del>	<del>30.9</del>	<del>902</del>	<del>2514</del>	<del>12.6</del>
<del>VOC</del>	<del>1.5</del>	<del>3.5</del>	<del>3.51</del>	<del>1.51</del>	<del>1.5</del>	4.5	1.1
<del>SO2</del>	<del>3.7</del>	3.71	4.02	4.01	<del>3.7</del>	<del>8.1</del>	<del>2.7</del>
PM10	9.0	<del>11.5</del>	<del>11.5</del>	9.0	<del>9.0</del>	<del>27</del>	9.0

<b>Pollutant</b>	Maximum Allowable Hourly Emissions					
	from Each Gas	Turbine/D	uct Burner			
	<u>(II</u>	<u>b/hour)</u>				
	In all modes of operation	<u>Start</u>	<u>Start</u>	<u>Shut</u>		
	except startup and shutdown Up Down					
	(lb/hour) (lb/startup) (lb/shutdow					
<u>NOx</u>	19.1 (1 hour average)	<u>175</u>	<u>680</u>	<u>80</u>		
CO	34.3 (3 hour average)	<u>902</u>	<u>2514</u>	<u>100</u>		
<u>VOC</u>	3.51 (3 hour average)	<u>16</u>	<u>59</u>	<u>16</u>		
<u>SO</u> <sub>2</sub>	4.02 (3 hour average) 3.7 22.2 3.7					
<u>PM<sub>10</sub></u>	11.5 (3 hour average)	<u>9</u>	<u>54</u>	<u>9</u>		

(12) For maximum project daily emissions (lbs/day) are given in the table below:

	Total Emissions per CTG	Calpine Maximum SPP Daily Emissions
<del>NOx</del>	<del>909</del>	<del>1817</del>
CO	<del>3264</del>	<del>6528</del>
<del>VOC</del>	<del>79</del>	<del>158</del>
<del>SO2</del>	<del>90</del>	<del>179</del>
PM10	<del>271</del>	<del>541</del>

<u>Pollutant</u>	<b>Maximum Allowable Daily Emissions</b>			
	from the Facility (A)			
	<u>(lb/day)</u>			
<u>NOx</u>	<u>1,817</u>			
CO	<u>6,528</u>			
<u>VOC</u>	<u>158</u>			
<u>SO</u> <sub>2</sub>	<u>179</u>			
<u>PM</u> <sub>10</sub>	<u>541</u>			

(A) Includes both combustion turbines and both duct burners

(13) The maximum quarterly emissions for the facility are given in the table below:

	January-March Ibs/quarter	April-June Ibs/quarter	July-September Ibs/quarter	October-December Ibs/quarter
<del>NOx</del>	<del>102,500</del>	<del>102,500</del>	<del>102,500</del>	<del>102,500</del>
<del>CO</del>	<del>241,600</del>	<del>241,600</del>	<del>241,600</del>	<del>241,600</del>

<del>VOC</del>	<del>11,850</del>	<del>11,850</del>	<del>11,850</del>	<del>11,850</del>
<del>SO2</del>	<del>15,750</del>	<del>15,750</del>	<del>15,750</del>	<del>15,750</del>
PM10	<del>46,200</del>	<del>46,200</del>	<del>46,200</del>	4 <del>6,200</del>

<u>Pollutant</u>	Maximum Allowable Quarterly Emissions							
	from the Facility (A)							
	January-	<u>January-</u> <u>April-</u> <u>July-</u> <u>October-</u>						
	<u>March</u>	<u>December</u>						
	(lb/quarter) (lb/quarter) (lb/quarter) (lb/quarter)							
<u>NOx</u>	<u>102,500</u>	<u>102,500</u>	<u>102,500</u>	<u>102,500</u>				
CO	<u>241,600</u>	<u>241,600</u>	<u>241,600</u>	<u>241,600</u>				
<u>VOC</u>	<u>11,850</u>	<u>11,850</u>	<u>11,850</u>	<u>11,850</u>				
<u>SO</u> <sub>2</sub>	<u>15,750</u>	<u>15,750</u>	<u>15,750</u>	<u>15,750</u>				
<u>PM<sub>10</sub></u>	<u>46,200</u>	<u>46,200</u>	<u>46,200</u>	<u>46,200</u>				

(A) Includes both combustion turbines and both duct burners

(14) The maximum annual calendar year emissions (tons/year) for the facility are given in the table below:

	Total Emissions per CTG	Calpine Annual SPP Emissions
<del>XOV</del>	<del>102</del>	<del>205.86</del>
CO	<del>242</del>	<del>483.18</del>
<del>VOC</del>	<del>11.9</del>	<del>24.41</del>
<del>SO2</del>	<del>15.7</del>	<del>31.5</del>
PM10	4 <del>3.2</del>	<del>92.5</del>

<u>Pollutant</u>	Maximum Allowable Calendar Year Emissions			
	from the Facility (A)			
	<u>(tons/year)</u>			
<u>NOx</u>	<u>205.0</u>			
CO	<u>483.2</u>			
<u>VOC</u>	<u>23.7</u>			
<u>SO</u> <sub>2</sub>	<u>31.5</u>			
<u>PM<sub>10</sub></u>	<u>92.4</u>			

(A) Includes both combustion turbines and both duct burners

<u>Verification:</u> As part of the <u>semi-annualguarterly</u> Air Quality Report (as required by AQ-430), the project owner shall provide all data required in this Condition. In the <u>semi-annualguarterly</u> Air Quality Reports (as required by AQ-430), the project owner shall indicate the date, time, and duration of any violation to the NOx, and VOC limits presented in this Condition. The project owner shall include in the <u>semi-annualguarterly</u> Air Quality Reports (as required by AQ-430) daily and annual emissions as required in this Condition.

#### **AQ-33** BACT Emission Limits:

The BACT emission limits (including duct burner emissions) specified in Conditions (a), (b), (c), (d), and (e) apply under all operating load rates at all times, except during CTG startups and shutdowns, as defined in Condition AQ-332. (FRAQMD specific ATC Permit Condition c).

- (a) NOx emission concentrations shall be limited to 2.5 ppmvd @ 15% O2 on a 1 hour rolling average, clock hour basis (based on readings taken at 15 minute intervals) and with a maximum of 10 ppmvd ammonia slip.
- (b) CO emission concentrations shall be limited to 4.0 ppmvd @ 15% O2, on a calendar day 3-hour average, clock hour basis.
- (c) VOC emission concentrations shall be limited to 1 ppmvd @ 15% O2, on a calendar day3-hour average, clock hour basis.
- (d) PM10 emissions shall be limited to 11.5 pounds per hour, on a calendar day 3-hour average, clock hour basis.
- (e) SO2 emission concentrations shall be limited to 1 ppmvd @ 15% O2, on a calendar day3-hour average, clock hour basis.

<u>Verification:</u> At least sixty (60) days before conducting a source test, the project owner shall submit to the District, <u>EPA</u> and the CPM for their review<u>and</u> approval, a <u>source test plan.</u> <u>detailed performance annual source test procedure designed to satisfy the requirements of this Condition. The project owner shall incorporate the District's and Commission's comments on or modifications to the procedure if any are received. The project owner shall also notify the District and the CPM within seven (7) working days before the project begins initial operation and/or plans to conduct <u>a</u> source tests as required by this Condition. All source test results shall be submitted to the CPM and District within <u>3060</u> days of the date of the tests.</u>

- AQ-34 Each CTG set exhaust vent stack shall be equipped with NOx and % oxygen (O2) CEMs in order to analyze and record exhaust gas flow rate and concentrations. CO, PM10, SO2, and VOC emissions shall be monitored by the CEMs, using source test derived algorithms as indicated in AQ-36 below. In the event that test results show that CO emission limits are exceeded, the APCO may require CEMs for recording concentrations of CO.

  Prior to the date of startup and thereafter, the project owner shall install, maintain, and operate the following CEM systems in each CTG exhaust vent stack:
  - (1) A continuous monitoring system to measure stack gas NOx concentrations. The system shall meet EPA monitoring performance specifications (40 CFR 75);

- (2) A continuous monitoring system to measure stack gas CO concentrations.

  The system shall meet EPA monitoring performance specifications (40

  CFR 60, Appendix B);
- (3) A continuous monitoring system to measure stack gas O2 concentrations. The system shall meet EPA monitoring performance specifications (40 CFR 75).

PM10, SO2, and VOC emissions shall be monitored by source test derived algorithms.

- (a) The NOx CEMs shall have the capability of recording NOx concentrations during all operating conditions, including startups and shutdowns.
- (b) The CO CEMs shall have the capability of recording CO concentrations during all operating conditions, including startups and shutdowns.
- (bc) Relative accuracy (RA) testing for NOx and O2 shall be performed on the CEMsS on a semi-annual basis or as required by the Acid Rain permit provisions in Title 40, CFR, Part 75, Appendix B. RA testing for CO shall be performed as required by 40 CFR Part 60, Appendix F. (FRAQMD specific ATC Permit Condition d).

<u>Verification:</u> At least one hundred and twenty (120) days before initial operation, the project owner shall submit to the District and the CPM a continuous emissions monitoring procedure. Within sixty (60) days of receipt of the procedure, the District and the CPM will advise the project owner of the acceptability of the procedure. <u>Based on the results of the source test identified in AQ-36, the District and CPM may require CEMs for recording concentrations of CO.</u>

- AQ-35 Within ninety days after the start of commercial operation of the SPP, source testing shall be performed to determine the mass emission rates and concentrations of NOx, CO, VOC, and SO2 emissions at four different steadystate CTG load rates over the expected operating range of either combustion turbine, as required by 40 CFR 60.335.c (2). The source testing will be used to determine compliance with the permitted emission limits indicated in Specific ATC Permit Conditions AQ-332 and AQ-343. Source testing shall be conducted to determine PM10 mass emissions and concentrations while the CTG is operating at 100 percent load with and without the duct burners, firing at the maximum rated capacity or 170 MMBtu/hr (HHV), whichever is greater.
  - (a) The sSource testing results shall be used to develop predictive emission algorithms to estimate mass emission rates for CO, VOC, and SO2, and PM10 emissions.

- (b) Source testing to determine the mass emission rates and concentrations of NOx shall be conducted annually after the initial source test indicated in a) above.
- (c) Source testing to determine the mass emission rates and concentrations of CO, VOC, SO2 and PM10 shall be conducted annually. <u>Startup source tests</u> for VOC shall be conducted once every seven years, beginning in the 2003 <u>calendar year</u>. The Air Pollution Control Officer <u>and the CPM</u> may waive annual source testing requirements if prior test results indicate an adequate compliance margin has been maintained. <del>(FRAQMD specific ATC Permit Condition e).</del>

<u>Verification:</u> At least sixty (60) days before the start of commercial operation of the project, the project owner shall submit to the District and the CPM for review a detailed performance test procedure necessary to comply with this Condition. The project owner shall incorporate the District and CPM's comments on or modifications to the procedure. At least sixty (60) days prior to any subsequent annual compliance source tests, the project owner shall submit to the District and the CPM for review any proposed changes to the original source test procedure. The project owner shall incorporate the District's and CPM's comments on or modifications to the annual source test procedure conducting a source test, the project owner shall submit to the District, CPM, and EPA for their review and approval, a source test plan. The project owner shall also notify the District and the CPM within seven (7) working days before the project begins initial operation and/or plans to conduct source testing as required by this Condition. All sSource test results shall be submitted to the District and the CPM within 3060 days of the date of the tests.

AQ-36 Source tests to determine ammonia slip shall be conducted within ninety days after commercial operation of the SPP and thereafter as required by the APCO and the CPM. (FRAQMD specific ATC Permit Condition f).

**Verification:** Please refer to AQ-365 verification.

AQ-37 The maximum allowable ammonia emission rate to from each of the SCR systems shall be not exceed 25 pounds per hour based on a 3-hour average under normal operating condition. Ammonia (slip) emissions shall not exceed 10 ppmvd at 15% O2 based on a 3-hour average. This injection rate may be adjusted based on source tests results. (FRAQMD specific ATC Permit Condition g).

**Verification:** Please refer to AQ-345 verification.

**AQ-38** Within ninety days after beginning commercial operation of the SPP, startup, and shutdown source tests shall be conducted to determine the emissions of CO and NOx. The APCO and CPM may approve the use of the NOx CEMS readings in

lieu of source testing if annual Relative Accuracy Testing Audits (RATA) testing is provided. (FRAQMD specific ATC Permit Condition h).

<u>Verification:</u> Within ninety days after the start of commercial operation of the project, the project owner shall submit to the District and the CPM for review a detailed performance source test procedure designed to satisfy the requirements of this Condition. The project owner shall incorporate the District's and Commission's comments on or modifications to the procedure. The project owner shall also notify the District and the CPM within seven (7) working days before the project begins commercial operation and/or plans to conduct source test as required by this Condition. Source test results shall be submitted to the District within 30 days of the date of the tests.

AQ-39 Records and logs of all data generated by CEMS and algorithms shall be maintained for a period of five (5) years. (FRAQMD specific ATC Permit Condition i).

<u>Verification:</u> During site inspection, the project owner shall make all data generated by the CEMS and algorithm, and included in the plant logs for a period of five years, available to the District, California Air Resources Board (CARB), and the Commission staff.

PLEASE NOTE THAT THIS CONDITION IS BASED ON A DISTRICT CONDITION (RECORD KEEPING AND REPORTING CONDITION NUMBER 46) THAT WAS MODIFIED AS SHOWN BELOW, WITH THE EXCEPTION OF THE BOLDED LANGUAGE WHICH HAS BEEN ADDED BY COMMISSION STAFF.

AQ-40 The project owner shall provide calendar quarterly reports to the District in a format determined in consultation with the District. The calendar quarterly reports shall include the following: CEMS and predictive algorithm emissions data; CTG and duct burner fuel use and operating hours; power augmentation steam injection rates and hours of operation; ammonia injection rates; emission control systems and CEMS hours of operation including the time, date, duration, and reason for any malfunctions of these systems; the number of startups and shutdowns; and the electrical and steam production rates. These data shall be averaged on a daily basis, except where required to demonstrate compliance with an emission limitation. (FRAQMD specific ATC Permit Condition j).

The project owner shall submit a written summary report to the District, CPM and U.S. EPA for every calendar quarter. The report shall include the following:

- (1) The hourly and daily emissions for each gas turbine/duct burner.
- (2) The facility-wide quarterly and yearly (fourth quarter report only) emissions.
- (3) The magnitude of excess emissions, any conversion factors used and the date and time of commencement and completion of each time period of excess emissions.

(4) Specific identification of each period of excess emissions that occurs during startups, shutdowns and malfunctions of the emission control systems. The nature and cause of any malfunction (if known) and the corrective action taken or preventative measures adopted shall also be reported. (5) The date and time identifying each period during which the CEM system was inoperative except for zero and span checks and the nature of the system repairs or adjustments. (6) When no excess emissions have occurred or the CEM system has not been inoperative, repaired, or adjusted, such information shall be stated in the report. (7) Gas turbine/duct burner hourly, daily and yearly (fourth quarter report only) fuel use in terms of mmBTU/hr (HHV). (8) Gas turbine quarterly startup, shutdown and operating hours. Include duration of each startup and shutdown. Include rolling 12-month average for duration of startups and shutdowns. Include an estimate of all emissions during startup and shutdown event (lbs/hour and lbs/event) based on the most recent source testing (include source test reference). (9) Duct burner quarterly operating hours (10) Power augmentation steam injection rates and quarterly hours of operation. (11) Ammonia injection rates. (12) Electrical and steam production rates.

<u>Verification:</u> Within 30 days of the end of the calendar quarter, the project owner shall provide to the District and CPM the data required in this Condition.

AQ-41 Prior to the start of construction, the SPP facility must provide ERC certificates for NOx, ROC, and PM10, as indicated in the table below. The ERC sources are Atlantic Oil Company, Ranch A, Ranch B, Ranch C, Ranch D, Ranch E, Spreckles Sugar Company, Tri Union, and Rosboro Lumber. Alternative sources of offsets may be used if they meet the criteria applied to these sources and are approved by the District and CPM. (FRAQMD specific ATC Permit Condition k).

<u>Verification:</u> At least 30 days prior to the start of construction, the project owner must submit a copy of the required ERC certificates to the CPM and the District.

AQ-42 The project owner must file a semi-annual air quality report with the CPM documenting the information required by these conditions and verifications.

<u>Verification:</u> The semi-annual Air Quality report (as required by AQ-43) must be submitted to the CPM within 30 days of the end of the 6 month reporting period.

<del>January-</del>	April-June	<del>July-</del>	October-	Total ERCs & Offsets	
March	<del>(pounds)</del>	September	December		
<del>(pounds)</del>	,	<del>(pounds)</del>	<del>(pounds)</del>		
,		,	,	Total Pounds	Total Tons

Required	<del>106,950</del>	<del>106,950</del>	<del>106,950</del>	<del>106,950</del>	<del>427,800</del>	<del>213.9</del>					
NOx											
Required	<del>69,300</del>	<del>69,300</del>	<del>69,300</del>	<del>69,300</del>	<del>277,200</del>	<del>138.6</del>					
<del>VOC</del>											
Required	<del>66,000</del>	<del>66,000</del>	<del>66,000</del>	<del>66,000</del>	<del>264,000</del>	<del>132.0</del>					
PM10											
These ERCs have I	These ERCs have not been discounted to reflect the appropriate offset distance ratio calculations.										

AQ-41 The following VOC ERCs have been provided to the Air Pollution Control Officer to comply with the requirements of Rule 10.1 - New Source Review:

Emission Reduction Credit		e Value tificates lb/qu			Inter- Pollutant Trading	Offset Ratio				
Certificate No.	Qtr 1	Qtr 2	Qtr 3	Qtr 4	Ratio		Qtr 1	Qtr 2	Qtr 3	<u>Qtr 4</u>
98001-01P Bio Fuel	<u>4522</u>	<u>4582</u>	<u>2521</u>	<u>5054</u>	<u>NA</u>	<u>1.2</u>	<u>3768</u>	<u>3818</u>	<u>2100</u>	<u>4211</u>
98001-02P Bio Fuel	<u>0</u>	<u>0</u>	4413	<u>0</u>	<u>NA</u>	1.2	<u>0</u>	<u>0</u>	<u>3677</u>	<u>0</u>
98002-00P Bio Fuel	<u>2512</u>	<u>1625</u>	<u>7286</u>	<u>2807</u>	<u>NA</u>	1.2	2093	1354	<u>6071</u>	2339
98003-00P Bio Fuel	3320	<u>4826</u>	<u>3</u>	<u>5711</u>	<u>NA</u>	1.2	<u>2766</u>	4021	<u>2</u>	<u>4759</u>
98005-00P Bio Fuel	<u>2814</u>	<u>1821</u>	<u>0</u>	<u>650</u>	<u>NA</u>	<u>1.2</u>	<u>2345</u>	<u>1517</u>	<u>o</u>	<u>541</u>
98010-00P Bio Fuel	<u>581</u>	<u>376</u>	<u>0</u>	<u>0</u>	<u>NA</u>	<u>1.2</u>	<u>484</u>	<u>313</u>	<u>0</u>	<u>0</u>
98012-00P Bio Fuel	<u>0</u>	993	<u>0</u>	<u>0</u>	<u>NA</u>	<u>1.2</u>	<u>0</u>	<u>827</u>	<u>0</u>	<u>0</u>
94-1-00P Rosboro	<u>473</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>NA</u>	1.2	<u>394</u>	<u>0</u>	<u>0</u>	<u>0</u>
						Total	11850	<u>11850</u>	11850	<u>11850</u>

The following NOx ERCs (or inter-pollutant traded VOC ERCs as noted) have been provided to the Air Pollution Control Officer to comply with the requirements of Rule 10.1 - New Source Review:

Emission Reduction Credit Certificate No.		Value of tificates lb/qu			Inter- Pollutant Trading	Offset Ratio	Value Applied to the Project NOx Emission Liability Ib/quarter			
	Qtr 1	Qtr 2	Qtr 3	Qtr 4	<u>Ratio</u>		Qtr 1	Qtr 2	Qtr 3	Qtr 4
98001-01P NOx Bio Fuel	<u>3798</u>	3282	<u>1528</u>	<u>4245</u>	<u>NA</u>	<u>1.2</u>	<u>3165</u>	<u>2735</u>	<u>1273</u>	<u>3537</u>
98001-02P NOx Bio Fuel	<u>0</u>	<u>0</u>	<u>2697</u>	<u>0</u>	<u>NA</u>	1.2	<u>0</u>	<u>0</u>	<u>2247</u>	<u>0</u>
98002-00P NOx Bio Fuel	<u>2110</u>	<u>1365</u>	<u>5094</u>	2358	<u>NA</u>	<u>1.2</u>	<u>1758</u>	1137	<u>4245</u>	<u>1965</u>

Emission		Value of tificates			<u>Inter-</u> Pollutant	Offset Ratio		Value Applied to the Project NOx Emission Liability			
Reduction Credit			arter		Trading		lb/quarter				
Certificate No.	Qtr 1	Qtr 2	Qtr 3	Qtr 4	Ratio		Qtr 1	Qtr 2	Qtr 3	Qtr 4	
98002-00P VOC Bio Fuel	<u>0</u>	<u>0</u>	884	<u>0</u>	2.0	1.2	<u>0</u>	<u>0</u>	368	<u>0</u>	
INTER-POLLUTANT	<u>~</u>		<u> </u>		<u>=</u>	<u></u>	_	<u> </u>	<u> </u>		
98003-00P NOx Bio Fuel	6265	4054	<u>1106</u>	7002	<u>NA</u>	1.2	<u>5220</u>	3378	<u>921</u>	<u>5835</u>	
98003-00P VOC Bio Fuel INTER-POLLUTANT	4138	<u>0</u>	<u>1313</u>	<u>0</u>	<u>2.0</u>	1.2	<u>1724</u>	<u>0</u>	<u>547</u>	<u>0</u>	
98005-00P NOx Bio Fuel	2364	<u>1529</u>	<u>417</u>	<u>2642</u>	<u>NA</u>	<u>1.2</u>	<u>1970</u>	1274	<u>347</u>	<u>2201</u>	
98005-00P VOC Bio Fuel INTER-POLLUTANT	<u>0</u>	<u>0</u>	<u>497</u>	<u>0</u>	2.0	1.2	<u>0</u>	<u>0</u>	<u>207</u>	<u>0</u>	
98010-00P NOx Bio Fuel	<u>488</u>	<u>316</u>	<u>86</u>	<u>546</u>	<u>NA</u>	1.2	<u>406</u>	<u>263</u>	<u>71</u>	<u>455</u>	
98010-00P VOC Bio Fuel INTER-POLLUTANT	<u>0</u>	<u>0</u>	<u>103</u>	<u>0</u>	<u>2.0</u>	<u>1.2</u>	<u>0</u>	<u>0</u>	<u>42</u>	<u>0</u>	
98012-00P NOx Bio Fuel	<u>3249</u>	<u>2103</u>	<u>573</u>	<u>3632</u>	<u>NA</u>	<u>1.2</u>	<u>2707</u>	<u>1752</u>	<u>477</u>	<u>3026</u>	
98012-00P VOC Bio Fuel INTER-POLLUTANT	3868	<u>0</u>	<u>683</u>	<u>0</u>	2.0	1.2	<u>1611</u>	<u>0</u>	<u>284</u>	<u>0</u>	
98021-00P NOx Bio Fuel	<u>1726</u>	1117	<u>305</u>	1929	<u>NA</u>	1.2	<u>1438</u>	<u>930</u>	<u>254</u>	<u>1607</u>	
98021-00P VOC Bio Fuel INTER-POLLUTANT	2054	<u>0</u>	<u>363</u>	<u>0</u>	2.0	<u>1.2</u>	<u>855</u>	<u>0</u>	<u>151</u>	<u>0</u>	
98022-00P NOx Bio Fuel	3249	2103	<u>573</u>	<u>3632</u>	<u>NA</u>	1.2	<u>2707</u>	<u>1752</u>	<u>477</u>	3026	
98022-00P VOC Bio Fuel INTER-POLLUTANT	<u>3868</u>	<u>0</u>	<u>683</u>	<u>0</u>	<u>2.0</u>	<u>1.2</u>	<u>1611</u>	<u>O</u>	<u>284</u>	<u>0</u>	
98023-00P NOx Bio Fuel	<u>3249</u>	<u>2103</u>	<u>573</u>	<u>3632</u>	<u>NA</u>	1.2	<u>2707</u>	<u>1752</u>	<u>477</u>	<u>3026</u>	
98023-00P VOC Bio Fuel INTER-POLLUTANT	<u>3868</u>	<u>0</u>	<u>683</u>	<u>0</u>	2.0	<u>1.2</u>	<u>1611</u>	<u>0</u>	<u>284</u>	<u>0</u>	
98024-00P NOx Bio Fuel	<u>3249</u>	2103	<u>573</u>	<u>3632</u>	<u>NA</u>	1.2	<u>2707</u>	<u>1752</u>	<u>477</u>	3026	
98024-00P VOC Bio Fuel INTER-POLLUTANT	<u>3868</u>	<u>0</u>	<u>683</u>	<u>0</u>	<u>2.0</u>	<u>1.2</u>	<u>1611</u>	<u>0</u>	<u>284</u>	<u>0</u>	
98025-00P NOx Bio Fuel	3249	2103	<u>573</u>	<u>3632</u>	<u>NA</u>	1.2	<u>2707</u>	<u>1752</u>	<u>477</u>	3026	
98025-00P VOC Bio Fuel INTER-POLLUTANT	<u>3868</u>	<u>0</u>	<u>683</u>	<u>0</u>	<u>2.0</u>	1.2	<u>1611</u>	<u>0</u>	<u>284</u>	<u>0</u>	
98027-00P NOx Bio Fuel	912	<u>590</u>	<u>161</u>	<u>1019</u>	<u>NA</u>	<u>1.2</u>	<u>760</u>	<u>491</u>	<u>134</u>	<u>849</u>	

<u>Emission</u>		Value of tificates			<u>Inter-</u> Pollutant	Offset Ratio			to the P	
Reduction Credit	001		arter	<del>ii cu</del>	Trading	itatio	NOx Emission Liability  Ib/quarter			
Certificate No.	Qtr 1	Qtr 2	Qtr 3	Qtr 4	Ratio		Qtr 1	Qtr 2	Qtr 3	Qtr 4
98027-00P VOC						4.0				
Bio Fuel INTER-POLLUTANT	<u>1085</u>	<u>0</u>	<u>192</u>	<u>0</u>	<u>2.0</u>	<u>1.2</u>	<u>452</u>	<u>0</u>	<u>80</u>	<u>0</u>
98028-00P NOx Bio Fuel	<u>1452</u>	<u>940</u>	<u>256</u>	<u>1623</u>	<u>NA</u>	<u>1.2</u>	<u>1210</u>	<u>783</u>	<u>213</u>	<u>1352</u>
98028-00P VOC Bio Fuel INTER-POLLUTANT	<u>483</u>	<u>0</u>	<u>305</u>	<u>0</u>	2.0	<u>1.2</u>	<u>201</u>	<u>0</u>	<u>127</u>	<u>0</u>
06-5-99-1 NOx Tri Union	<u>6280</u>	<u>6280</u>	<u>6280</u>	<u>6280</u>	<u>NA</u>	<u>1.2</u>	<u>5233</u>	<u>5233</u>	<u>5233</u>	<u>5233</u>
06-5-99-1 VOC Tri Union	<u>0</u>	<u>0</u>	<u>140</u>	<u>0</u>	<u>2.0</u>	1.2	<u>0</u>	<u>0</u>	<u>58</u>	<u>0</u>
98-101-00P NOx Tri Union	3334	3371	3408	3408	<u>NA</u>	1.2	2778	2809	2840	<u>2840</u>
992024-00P NOx Tri Union	<u>16986</u>	<u>16986</u>	<u>16986</u>	<u>16986</u>	<u>NA</u>	<u>1.2</u>	<u>14155</u>	<u>14155</u>	<u>14155</u>	<u>14155</u>
992024-00P VOC Tri Union INTER-POLLUTANT	<u>0</u>	<u>0</u>	<u>261</u>	<u>0</u>	2.0	<u>1.2</u>	<u>0</u>	<u>0</u>	<u>108</u>	<u>0</u>
95-1-00P NOx Atlantic Oil	<u>10955</u>	10955	10955	<u>10955</u>	<u>NA</u>	<u>1.2</u>	9129	<u>9129</u>	9129	9129
95-1-00P VOC Atlantic Oil	<u>0</u>	<u>0</u>	<u>2526</u>	<u>0</u>	2.0	<u>1.2</u>	<u>0</u>	<u>0</u>	<u>1052</u>	<u>0</u>
9902005-00P NOx Atlantic Oil	<u>5683</u>	<u>5683</u>	<u>5683</u>	<u>5683</u>	<u>NA</u>	1.2	<u>4735</u>	<u>4735</u>	<u>4735</u>	<u>4735</u>
9902005-00P VOC Atlantic Oil INTER-POLLUTANT	<u>0</u>	<u>0</u>	<u>53</u>	<u>0</u>	2.0	<u>1.2</u>	<u>0</u>	<u>0</u>	<u>22</u>	<u>0</u>
9902029-00P NOx Atlantic Oil	<u>3648</u>	<u>3648</u>	<u>3648</u>	<u>3648</u>	<u>NA</u>	1.2	3040	3040	3040	<u>3040</u>
9902029-00P VOC Atlantic Oil INTER-POLLUTANT	<u>0</u>	<u>0</u>	<u>39</u>	<u>0</u>	2.0	1.2	<u>0</u>	<u>0</u>	<u>16</u>	<u>0</u>
9902030-00P NOx Atlantic Oil	<u>4536</u>	<u>4536</u>	<u>4536</u>	<u>4536</u>	<u>NA</u>	1.2	3780	3780	<u>3780</u>	<u>3780</u>
9902030-00P VOC Atlantic Oil INTER-POLLUTANT	<u>0</u>	<u>0</u>	<u>65</u>	<u>0</u>	2.0	<u>1.2</u>	<u>0</u>	<u>0</u>	<u>27</u>	<u>0</u>
94-1-00P NOx Rosboro	21134	21134	21134	18850	<u>NA</u>	1.2	<u>17611</u>	<u>17611</u>	<u>17611</u>	<u>15708</u>
94-1-00P VOC Rosboro INTER-POLLUTANT	<u>1760</u>	<u>0</u>	<u>1920</u>	<u>0</u>	<u>2.0</u>	1.2	<u>733</u>	<u>0</u>	800	<u>0</u>
EC-0002 Spreckles YSAQMD	<u>0</u>	<u>0</u>	24000	<u>0</u>	<u>NA</u>	<u>1.5</u>	<u>0</u>	<u>0</u>	16000	<u>0</u>
EC-0058 Spreckles YSAQMD	<u>103</u>	<u>3632</u>	<u>0</u>	<u>0</u>	<u>NA</u>	<u>1.5</u>	<u>68</u>	<u>2421</u>	<u>0</u>	<u>0</u>

Emission Reduction Credit Certificate No.	Face Value of NOx/VOC ERC Certificates Surrendered Ib/quarter				Inter- Pollutant Trading	Offset Ratio	Value Applied to the Project NOx Emission Liability Ib/quarter			-
Certificate No.	<u>Qtr 1</u>	Qtr 2	Qtr 3	<u>Qtr 4</u>	<u>Ratio</u>		<u>Qtr 1</u>	Qtr 2	<u>Qtr 3</u>	<u>Qtr 4</u>
EC-0059 Spreckles YSAQMD	<u>279</u>	23107	<u>1205</u>	<u>8646</u>	<u>NA</u>	<u>1.5</u>	<u>186</u>	<u>15404</u>	<u>803</u>	<u>5764</u>
EC-0060 Spreckles YSAQMD	<u>328</u>	<u>6649</u>	<u>8698</u>	<u>7778</u>	<u>NA</u>	<u>1.5</u>	<u>218</u>	<u>4432</u>	<u>5798</u>	<u>5185</u>
EC-0061 Spreckles YSAQMD	<u>128</u>	<u>0</u>	<u>3392</u>	<u>0</u>	<u>NA</u>	<u>1.5</u>	<u>85</u>	<u>0</u>	<u>2261</u>	<u>0</u>
	<u>Total</u>									

## The following PM<sub>10</sub> ERCs have been provided to the Air Pollution Control Officer to comply with the requirements of Rule 10.1 - New Source Review:

Emission Reduction Credit Certificate No.	Certificates Surrendered Ib/quarterPollutant TradingRatioPM1						0 Emiss	Applied to the Project 0 Emission Liability lb/quarter			
Certificate No.	<u>Qtr 1</u>	<u>Qtr 2</u>	<u>Qtr 3</u>	<u>Qtr 4</u>	<u>Ratio</u>		<u>Qtr 1</u>	<u>Qtr 2</u>	<u>Qtr 3</u>	<u>Qtr 4</u>	
98001-01P Bio Fuel	<u>5087</u>	<u>5683</u>	<u>3387</u>	<u>5685</u>	<u>NA</u>	<u>1.2</u>	<u>4239</u>	<u>4735</u>	<u>2822</u>	<u>4737</u>	
98001-02P Bio Fuel	<u>0</u>	<u>0</u>	<u>5884</u>	<u>0</u>	<u>NA</u>	<u>1.2</u>	<u>0</u>	<u>0</u>	<u>4903</u>	<u>0</u>	
98002-00P Bio Fuel	<u>2826</u>	<u>1828</u>	<u>10801</u>	<u>3158</u>	<u>NA</u>	<u>1.2</u>	<u>2355</u>	<u>1523</u>	9000	<u>2631</u>	
98003-00P Bio Fuel	<u>8390</u>	<u>5429</u>	<u>1481</u>	<u>9378</u>	<u>NA</u>	<u>1.2</u>	<u>6991</u>	<u>4524</u>	<u>1234</u>	<u>7815</u>	
98005-00P Bio Fuel	<u>3166</u>	<u>2048</u>	<u>559</u>	<u>3538</u>	<u>NA</u>	<u>1.2</u>	<u>2638</u>	<u>1706</u>	<u>465</u>	<u>2948</u>	
98010-00P Bio Fuel	<u>654</u>	<u>423</u>	<u>115</u>	<u>731</u>	<u>NA</u>	<u>1.2</u>	<u>545</u>	<u>352</u>	<u>95</u>	<u>609</u>	
98012-00P Bio Fuel	<u>4352</u>	<u>2816</u>	<u>768</u>	<u>4864</u>	<u>NA</u>	<u>1.2</u>	<u>3626</u>	2346	<u>640</u>	<u>4053</u>	
98021-00P Bio Fuel	<u>2311</u>	<u>1495</u>	<u>408</u>	<u>2583</u>	<u>NA</u>	<u>1.2</u>	<u>1925</u>	<u>1245</u>	<u>340</u>	<u>2152</u>	
98022-00P Bio Fuel	<u>4352</u>	<u>2816</u>	<u>768</u>	<u>4864</u>	<u>NA</u>	1.2	3626	2346	<u>640</u>	<u>4053</u>	
98023-00P Bio Fuel	<u>4352</u>	<u>2816</u>	<u>768</u>	<u>4864</u>	<u>NA</u>	1.2	<u>3626</u>	2346	<u>640</u>	<u>4053</u>	
98024-00P Bio Fuel	<u>4352</u>	<u>2816</u>	<u>768</u>	<u>4864</u>	<u>NA</u>	1.2	<u>3626</u>	2346	<u>640</u>	<u>4053</u>	
98025-00P Bio Fuel	<u>4352</u>	<u>2816</u>	<u>768</u>	<u>4864</u>	<u>NA</u>	1.2	<u>3626</u>	2346	<u>640</u>	<u>4053</u>	
98027-00P Bio Fuel	1221	<u>790</u>	<u>215</u>	<u>1365</u>	<u>NA</u>	1.2	<u>1017</u>	<u>658</u>	<u>179</u>	1137	
98028-00P Bio Fuel	<u>1945</u>	1258	<u>343</u>	2174	<u>NA</u>	1.2	<u>1620</u>	1048	<u>285</u>	<u>1811</u>	
06-5-99-1 Tri Union	<u>31</u>	<u>31</u>	<u>31</u>	<u>31</u>	<u>NA</u>	<u>1.2</u>	<u>25</u>	<u>25</u>	<u>25</u>	<u>25</u>	

Emission Reduction Credit Certificate No.	Face Value of PM10 ERC Certificates Surrendered Ib/quarter				Inter- Pollutant Trading	Offset Ratio	Value Applied to the Project PM10 Emission Liability Ib/quarter			
Certificate No.	<u>Qtr 1</u>	Qtr 2	<u>Qtr 3</u>	<u>Qtr 4</u>	<u>Ratio</u>		<u>Qtr 1</u>	Qtr 2 Qtr 3	<u>Qtr 4</u>	
94-1-00P Rosboro	<u>8058</u>	<u>14638</u>	<u>13561</u>	<u>2484</u>	<u>NA</u>	<u>1.2</u>	<u>6715</u>	<u>12198</u>	<u>11300</u>	<u>2070</u>
EC-0060 Spreckles YSAQMD	<u>O</u>	<u>9684</u>	<u>18528</u>	<u>0</u>	<u>NA</u>	<u>1.5</u>	<u>O</u>	<u>6456</u>	<u>12352</u>	<u>0</u>
	O. Co.							<u>46200</u>	<u>46200</u>	<u>46200</u>

**Verification:** At least 30 days prior to the start of construction, the project owner must submit a copy of the required ERC certificates to the CPM and the District.

IT IS SO ORDERED:

Date: June 11, 2003

STATE OF CALIFORNIA ENERGY RESOURCES CONSERVATION AND DEVELOPMENT COMMISSION

Original Signed By

WILLIAM J. KEESE

Chairman

20